

## **ADDENDUM NO. 1**

Filter Media Replacement  
Springfield, Tennessee 37172  
Bid Number 1158

The Addendum is a part of the bid specifications for the Filter Media Replacement project dated March 3<sup>rd</sup>, 2021.

Please refer to the following filter anthracite quantity with the associated specifications for the anthracite material. The new quantity value will be as listed below, replacing the original value.

3,876 cubic feet

Filter Anthracite – 18” Depth plus 3%  
1” skimming allowance  
Effective size: 0.95 mm to 1.05 mm  
Uniformity coefficient: 1:30