



RFP #2023-006 BACKFLOW TESTING AND INSTALLATION

ADDENDUM 1

Return to: Lumpkin County Board of Commissioners
Ryan McDuffie, Purchasing Agent
99 Courthouse Hill, Suite D
Dahlonega, GA 30533

Bid Closing Date: May 23, 2023 at 2:00 PM, EDT

Bid Issue Date: April 26, 2023

Addendum Issue Date: May 17, 2023 at 5:00 PM, EST

Pages: 2

By: Ryan McDuffie, Purchasing Agent

Vendor Name: _____
(A copy must be attached to the Addenda Acknowledgement)

-
1. Does the County require both a plumbing license and backflow license?
 - a. Yes.
 2. Do the preventors have to be installed outside of office hours?
 - a. The County will work with each location to attempt to identify a time during office hours when the selected vendor could install/inspect the item needed.
 3. Does the County want preventors or RPZ on the irrigation systems?
 - a. Yes. See attached building information sheet.
 4. Do fire vault backflows need to be inspected?
 - a. Yes. See attached building information sheet.
 5. Do all preventors need to be installed externally?
 - a. Not necessarily. This will really depend on the location. See attached building information sheet.

*****Please make sure to use the new building information sheet for pricing. Disregard the pricing sheet in the RFP document.

| Building Name | Size | Test or Install Backflow Prevention | Box Type | Additional Notes | Price |
|---------------------------|--------|-------------------------------------|----------|---|-----------|
| Kelley Building | 2" | Test Only | N/A | | |
| Annex | 1 1/2" | Test Only | N/A | | |
| Rainbow Office | 3/4" | Install Backflow (In Dirt) | Steel | | |
| Rainbow House | 3/4" | Install Backflow (In Concrete) | Steel | | |
| Classic Cleaners | 3/4" | Install Backflow (In Dirt) | Steel | Tight Location | |
| Administration Building | 3" | Test Only | N/A | | |
| Old Planning Building | 1" | Install Backflow (In Dirt) | Steel | Tight Location | |
| Historical Jail/Cannery | 3/4" | Install Backflow (In Dirt) | Steel | | |
| Elections | 1" | Install Backflow (In Dirt) | Plastic | | |
| Detention Center | 8" | Test Only | N/A | Fire Line (Front Vault) | |
| | 3/4" | Test Only | N/A | Fire Line (Front Vault) | |
| | 3" | Test Only | N/A | Domestic Line | |
| | 2" | Test Only | N/A | Domestic Line | |
| | 8" | Test Only | N/A | Fire Line (Side Vault) | |
| | 3/4" | Test Only | N/A | Fire Line (Side Vault) | |
| Mental Health | 1" | Install Backflow (In Dirt) | Plastic | Both lines can be installed in a single jumbo plastic box. Both are on deep risers. | |
| | 1" | Install Backflow (In Dirt) | Plastic | | |
| Station 1 | 2" | Test Only | N/A | | |
| Library | 8" | Test Only | N/A | Fire Line | |
| | 3/4" | Test Only | N/A | Fire Line | |
| | 2" | Test Only | N/A | Domestic Line | |
| | 3/4" | Test Only | N/A | Irrigation Line | |
| Health Department | 1" | Install Backflow (RPZ) (In Dirt) | N/A | This is an RPZ, above ground | |
| Head Start/Pre-K | 1" | Install Backflow (In Dirt) | Plastic | | |
| | 1" | Install Backflow (In Dirt) | Plastic | | |
| Justice Center | 3/4" | Install Backflow (In Dirt) | Plastic | Irrigation Line | |
| | 6" | Test Only | N/A | Fire Line | |
| | 3/4" | Test Only | N/A | Fire Line | |
| | 3" | Test Only | N/A | Domestic Line | |
| Senior Center | 2" | Test Only | N/A | | |
| Community Center | 4" | Test Only | N/A | Fire Line | |
| | 3/4" | Test Only | N/A | Fire Line | |
| | 2" | Test Only | N/A | Domestic Line | |
| Concession Stand Field #5 | 3/4" | Install Backflow (In Dirt) | Plastic | | |
| Softball Complex | 2" | Test Only | N/A | | |
| Yahoola Creek Park | 2" | Test Only | N/A | | |
| Communiity House | 3/4" | Install Backflow (In Dirt) | Plastic | | |
| Fueling Station | 3/4" | Install Backflow (In Dirt) | Plastic | | |
| TOTAL | | | | | \$ |