

**Addendum No. 1
W 6th Street Improvements
City of Prattville Bid No. 023-004
Civil Southeast Project No: 22P2408**

City of Prattville

APR 13 23 2:56PM

This Addendum forms a part of the Contract Documents and modifies the original Contract Documents as described. Acknowledge receipt of this Addendum in the space provided in the Proposal.

Mandatory Pre-Bid Meeting Notes

- See attached notes.

Revised Construction Plans

Replace the following Sheets in the Construction Plans dated 3/17/2023:

- Sheet 2A – added filter fabric call out and note.
- Sheet 3 – updated items & quantities.
- Sheet 10 – updated Storm Structure No. 1
- Sheet 11A – added sheet.

Revised Proposal Sheet

Replace the original proposal sheet with the attached proposal sheet dated 4/10/2023.

The following items have been revised/added:

- Item 25: 6" PVC SDR 26 Service Lateral – revised quantity.
- Item 29: Remove Existing Drainage Pipe – revised quantity.
- Item 30: 18" Reinforced Concrete Pipe, Class III – added item.
- Item 33: Open Throat Inlet (Elongated Structure) – added item. This item is intended for Storm Structure No. 1.
- Item 46: Misc. Drainage Improvements Allowance – allowance amount reduced.
- Removed Filter Fabric Pay Item.

Contract Time

Contract time shall hereby be revised to **120 Working Days**.

Clarification/RFI Responses

- All cost associated with removal of the existing sanitary sewer service laterals shall be included in the price for Pay Item 25: 6" PVC-SDR 26 Service Lateral.
- Estimated number of service connection to 16" Line – 26 EA
- Estimated number of service connections to 12" Line – 10 EA
- Estimated number of service connections to 8" Line – 2 EA