ADDENDUM NO. _1_

RFB NO:	305063
DATE BIDS DUE:	April 19, 2018
TIME:	2:00 PM
DEPARTMENT:_	Waste Resources
SUBJECT:	Uncoated Sewer Pipe
	Clarification
"Uncoated" was a poor word choice to describe the sewer pipe to be supplied.	
The pipe will be tar	coated and cement lined. Please bid accordingly.
(SIGNED)	
COMPANY:	
PLEASE SIGN THI	