

Addendum No. 5
A New Training Facility For Prattville Fire & Police Departments
City of Prattville
PRATTVILLE, ALABAMA
City of Prattville Bid No. 024-002

FEB 1 24 1:13PM

This Addendum forms a part of the Contract Documents and modifies the original Contract Documents as described. Acknowledge receipt of this Addendum in the space provided in the Proposal.

Revised Construction Plans

Replace the following sheets in the provided plan set with the attached sheets.

- Sheet C5
- Sheet A1

Clarifications/Additional Instructions

- See revised Sheet A1 dated 2/29/2024 regarding overhead doors.
- See attached revised sheet C5 regarding the fire supply line. The contractor shall be responsible for confirming the required line size from the existing water main to the building as required to support the contractor provided fire sprinkler system design and installation. The contractor shall be responsible for coordinating all water taps with Prattville Water Works. 6" valve shall be a Mueller resilient seat gate valve (nut operated) with a DI valve box or approved equal.

End of Addendum No. 5