



## Oconee County Board of Commissioners

### Addendum 2

**DATE:** December 10, 2021

**TO:** All Prospective Bidders/Offerors

**FROM:** Procurement Officer

**RE:** Addendum 2, RFQP# 22-11-005 Elevated Tank Maintenance Program

---

The following changes are to be incorporated into the solicitation documents dated **November 16, 2021**. All those receiving this addendum should modify their documents to show the below described changes.

1. Below you will find information regarding elevation of the water storage tanks.

All questions shall be directed to the Owner Contact, Jessica Ellis, Procurement Officer via email to [ocbids@oconee.ga.us](mailto:ocbids@oconee.ga.us) .

---

<b>ELEVATED STORAGE TANK CHARACTERISTICS</b>					
<b>Name</b>	<b>Capacity (gal)</b>	<b>Tank Diameter (ft)</b>	<b>Bottom Bowl Elevation (ft)</b>	<b>Overflow Elevation (ft)</b>	<b>Bottom/Top difference (ft)</b>
Dove Creek	250,000	43	981.6	1010.0	28.4
Mars Hill No. 1	1,000,000	70	934.0	974.0	40.0
Mars Hill No. 2	500,000	50	936.5	974.0	37.5
Watkinsville No. 1	250,000	43	894.5	920.0	25.5
Watkinsville No. 2 (Under Construction)	750,000	64	885.0	920.0	35.0

End of Addendum 2