

**NOTICE OF SOLICITATION: INVITATION TO BID #FY25-CP-E01
BULLOCH COUNTY TRANSPORTATION IMPROVEMENT PROGRAM**



**Bulloch County Board of Commissioners
Engineering Department and the Office of Capital Projects**

DATE: 07/15/2024

PROJECT: FY25-CP-E01, Brannen Pond Road Drainage Repairs Project

QUESTIONS/RESPONSES: Round 1

NO.	QUESTION	RESPONSE	REMARKS
1	Will Bulloch Co. allow a GDOT approved precast culvert in lieu of cast in place? Aprons / Wingwall Footers will be poured in place per detail requirements.	Bulloch County does not object to the use of GDOT approved precast box culverts on this Project. The Bidder's attention is directed to the Notice of Solicitation – Invitation to Bid, Time Allowed for Performance, Substantial Completion of the work and Final Acceptance of the work.	Question closed.