

	<h1>City of Wilson, NC.</h1> <h2>Addendum 2</h2>
<p><u>Please send inquiries and questions about this RFP to:</u></p>	<p>RFP: 2020-04</p>
<p>Ricky Wilson</p>	<p>RFP Due Date: July 6th 2020</p>
<p>Purchasing Manager rvwilson@wilsonnc.org</p>	<p>Contract Type (Purchase): LED Roadway and Area Luminaires</p>

Failure to acknowledge and return this addendum may subject your bid to be rejected based on the below information.

Vendor: _____

Question 1: It appears that the BUG rating on 3.3 and 3.4 are switched incorrectly. You cannot have a BUG rating of 1-0-1 and 15,000 lumens. If you look on 3.5 the BUG rating is 1-0-1. **Correct, 3.3 and 3.4 were switched incorrectly.**

Question 2: Also verify that the color on 3.7 is gray and should not be green. Most long life photo controls are either green or black. **We prefer gray but would also accept black if that's available.**

Question 3: Is there an approved list of manufacturers or fixture suppliers for this solicitation? **There is not a list of approved manufacturers, vendors, or suppliers. The specifications should match according to what our electrical department has submitted in the bid document.**

Question 4: Does this bid provide any scoring or set-aside for HUB or SDVOSB firms? **There is not scoring or set-aside for HUB businesses for this particular bid. This is a purchase contract and we are just requesting bids on the product itself, this is not a construction and repair contract so, scoring will not be required. We are providing outreach to registered HUB vendors with the State of NC for an opportunity to bid through the NC IPS website and it is also located on our Vendor Registry solicitation platform through our city website.**