

**CITY OF BEAUFORT**  
**RFP 2020 – 106 STORM PANELS FOR DISASTER MITIGATION**  
**Questions and Answers Submitted by March 18, 2020**  
**Questions & Answers posted by March 24, 2020.**

- 1. Question: Can you provide the required specifications of the Storm Panels?**

**Answer:**

**The windborne debris protection shall comply with 2018 IBC 1609.2.**

- 2. Question: What is the required maximum wind speed tolerance of the Storm Panels?**

**Answer:**

**The wind speed shall be 140 mph. See the attachment from ATC**