



## Jackson County Board of Commissioners

67 Athens Street  
Jefferson, Georgia 30549  
Phone: (706) 367-6309  
Fax: (706) 708-2505  
Email: [myarbrough@jacksoncountygov.com](mailto:myarbrough@jacksoncountygov.com)

Date: June 3, 2019

To: HVAC Companies

From: Myrna Yarbrough, Purchasing Manager

**RE: Addendum 2 to Jackson County ITB 190012, Repair Chiller at Courthouse**

1. Addendum 2 is hereby issued to answer submitted questions. Contractor should rebuild slide valve with new gaskets and seals and do not replace the piston and hardware. If slide valve meets manufacturer wear and tear and is within tolerance, contractor should reuse the slide valve. If we determine that the slide valve must be replaced, we will address it by change order. Please provide the cost of the slide valve at the bottom of this addenda page and attach it to your bid.
2. All other terms and conditions in ITB 190012 remain unchanged.
3. Any inquiries concerning Addendum 2 should be made to Myrna Yarbrough, Purchasing Manager, (706) 367-6309 or via email at [myarbrough@jacksoncountygov.com](mailto:myarbrough@jacksoncountygov.com)
4. Jackson County reserves the right to reject any and all proposals, to waive any technicalities or irregularities and to award the offer based upon the most responsive, responsible submission.
5. Bidders must acknowledge receipt of addenda, by either signing and attaching this copy, or by writing "Acknowledge Addenda #2" at bottom of Bid Schedule.
6. Cost of new slide valve = \$ \_\_\_\_\_