



Jayne Burritt, Administrator/CEO

Board of Directors

Heather Anderson, Chair

Ann Marie Tugwell, Vice Chair

Shane Jackson, Treasurer

Adam Cook, Secretary

Solicitation Number: 2024.010

Addendum Date: February 21, 2024

Addendum Number: 4

Closing Date: March 6, 2024 @ 11:00 A.M. Eastern Time

Total Pages: 2

Jon Clark

Scott Davis

Brian Gard

Rob Glass

Chuck Severance

John Wright

Questions/Answers:

Question #1: KAT Transit- What is the existing soil depth?

Answer #1: 6" with trays/soilless media

Question #2: KAT Transit- Is there an irrigation system present? If yes, is it functional and is it drip or spray irrigation?

Answer #2: Yes the irrigation system is present and functional. It is drip.

Question #3: KAT Transit- When was the last time this green roof was regularly maintained? When was the last known maintenance visit?

Answer #3: November 2023 was the last maintenance visit.

Question #4: KAT Transit- How is the green roof accessed?

Answer #4: Exterior ladder

Question #5: Are photos of the existing green roofs from the previous growing season available?

Answer #5: No

Question #6: City County Building- What is the existing soil depth?

Answer #6: 4"/shale

Question #7: City County Building- Is there an irrigation system present? If yes, is it functional and is it drip or spray irrigation?

Answer #7: No

Question #8: City County Building- When was the last time this green roof was regularly maintained? When was the last known maintenance visit?

Answer #8: November 2023 was the last maintenance visit.

Question #9: City County Building- How is the green roof accessed?

Answer #9: Floor Level 1 via elevator

Question #10: City Public Works- What is the existing soil depth?

Answer #10: 6" with trays/soilless media

Question #11: City Public Works- Is there an irrigation system present? If yes, is it functional and is it drip or spray irrigation?

Answer #11: No

Question #12: City Public Works- When was the last time this green roof was regularly maintained? When was the last known maintenance visit?

Answer #12: November 2023 was the last maintenance visit.

Question #9: City Public Works- How is the green roof accessed?

Answer #9: via the 2nd floor

End of Addendum #4.

Addenda must be acknowledged in Tab III of the submittal.



Brittany Daniels
Procurement Specialist
Public Building Authority