



# Dinwiddie County Administration Office

14010 Boydton Plank Road  
Dinwiddie, VA 23841  
Phone: (804) 469-4500  
Fax: (804) 469-4503  
E-Mail: [hcasey@dinwiddieva.us](mailto:hcasey@dinwiddieva.us)

## **ADDENDUM #1**

Date: September 9, 2020

Invitation For Bids # 20-082720

McKenney Fire Station Apron Replacement

Deadline: Tuesday, September 15, 2020 at 2 p.m.

TO ALL POTENTIAL BIDDERS:

The following information is being provided for purposes of clarification or in response to questions received from potential bidders. In the event that any of these specifications conflict with previous specifications, the specifications in this addendum shall control. Prepare your bids accordingly:

1. Additional Information regarding Alternate Bid Item #1
  - a) Alternate bid item #1 includes demolishing and replacing the following sections of concrete sidewalk:
    - 105 linear feet of 5' wide concrete sidewalk adjacent the parking area on the southeast side of the fire station
    - 15 linear feet of 6' wide sidewalk leading to the southeast fire station entrance
    - 74 linear feet of 5' wide sidewalk adjacent the northeast side of the fire station
    - 10 linear feet of 4' wide sidewalk leading to the flag pole on the northeast side of the fire station
  - b) The concrete at the northeast entrance beneath the entry canopy is excluded from the alternate bid.
  - c) Provide sidewalk per the sidewalk pavement section on sheet C-501. Existing sidewalk base materials shall remain.
  - d) Where new sidewalk abuts adjacent concrete and vertical surfaces, provide isolation joints per the isolation joint detail on sheet C-501.
  - e) Provide a 5'x5' section of 7" thick concrete pavement section at the western-most end of the 105 linear feet of 5' wide concrete sidewalk adjacent the parking area on the southeast side of the fire station.
  - f) Provide CG-12 detectable warning surface where concrete abuts handicapped parking aisle striping (two locations, 13 linear feet total).
  - g) Provide CG-12 detectable warning surface where concrete abuts a traveled way (two locations, 10 linear feet total).

**Note: A signed acknowledgement of this addendum must be received by this office prior to the due date and time, or must be attached to your bid. Signature on this addendum does not constitute signature on the original bid document. The original bid document must also be signed per bid instructions.**

Company Name: \_\_\_\_\_

Signature: \_\_\_\_\_

Type/Print Name: \_\_\_\_\_

Title: \_\_\_\_\_

Date: \_\_\_\_\_