



THE CITY OF DAYTONA BEACH
OFFICE OF THE PURCHASING AGENT

Post Office Box 2451
Daytona Beach, Florida 32115-2451

Phone (386) 671-8080
Fax (386) 671-8085

ADDENDUM NO. 2

DATE: June 22, 2018

PROJECT: ITB 0218-1870
BETHUNE POINT UPS-UV BATTERY REPLACEMENT

OPENING DATE: July 6, 2018

This addendum is hereby incorporated into the Bid Documents for the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to and shall take precedence over the original documents. Additions are indicated by underlining, deletions are indicated by ~~strikethrough~~.

1. Answers to Bidders' written questions:

Q1: Specs say you'll accept a 540WPC or 500WPC. But technically the compatible model is the 500WPC. Do you want the bid to reflect 540WPC or 500WPC

A1: 540 WPC

2. Page 22, Section 1C: "Batteries shall replace CSB HRL12500WFR with FIAMM (FLX12-540) or Energys (HX12-540) ~~or the latest comparable model batteries or approved equal~~ or the latest 540WPC comparable model batteries"
3. All other terms and conditions remain the same.

The Bidder shall acknowledge receipt of this addendum on the Bid Proposal Form.

The City of Daytona Beach
Kirk Zimmerman, CPPB
Buyer

In order to continue to be notified of bid opportunities make sure that you are registered with our new bid notification system. Visit www.codb.us go to departments, purchasing, vendor registration. Or visit www.vendorregistry.com and register under Daytona Beach.