



Opportunity in every direction.

Office of the Purchasing Director

Memo To: Certified Divers

From: Linda Jones, CPPB

Date: September 8, 2021

Subject: Addendum #1 Bid # FY22-03 Tank Cleaning with Diving Services

Questions:

- 1) Can sediment from the tank cleaning be discharged on-site? **Needs to be remove to the RIB site 4 miles away.**
- 2) How much sediment is to be expected in each tank? **Please refer to the attached reports. Also the video report. Those are the only reports that we have to go by.**
- 3) How many plumbing components are required to be re-coated with Epoxy, and how large are they? **Only the piping in the tank will required epoxy.**
- 4) Is there a surfaces perpetration that is required to be meet prior to coating application? **No.**
- 5) Is there a specific type of epoxy coating or general coating spec that should be used to re-coating all plumbing components? **No.**
- 7)What is the size of the water access hatch for Tank #2? **The opening is 4.5ft X 3ft.**
- 8)Is there an internal ladder in tank #2? **No.**
- 9) Please specify which “internal plumbing is to have epoxy applied. **Only the pipe in the tank that cannot be removed.**
- 10) Will the facility be “locked out/tagged out” for the duration of the project? **No, the tank will not be locked out, it will be in operation.**



Office of the Purchasing Director

Submit signed addendum #1 with your bid proposal.

Print Name

Signature

Company Name

Date