



Memo To: Certified Divers

From: Linda Jones, CPPB

Date: September 8, 2021

Subject: Addendum #2 Bid # FY22-03 Tank Cleaning with Diving Services

Questions: (These questions were accidentally left off addendum #1)

1. Where is the sediment from the two tanks to be pumped to? Public street, sewer drains, etc.? Hauled to the RIB Site.
2. What is the depth of the sediment in the #2 tank (25,000 Gal.)? Unknown but approximately 3 feet.
3. What type of epoxy is required for coating the pipes? The type approved by AWWA.
4. What are the pipe sizes and lengths? Estimated 16in 25 feet.
5. The pricing sheet on page 9 of 40 has no line item for the epoxy coating. Include in your bid.
6. My company usually pumps the sediment to holding bags that filter the sediment out with flocculants, releasing clean water. Is there a place (or places) at site that can be used for that? Yes
7. Using Google Earth, the dimensions show a 102 ft. x 102 ft. tank, not the bid documents dimensions of 120ft. X 120ft. Also the smaller tank on Google Earth measures 28ft. in diameter. Please clarify. We measured 120ft the 28Ft is close.
8. Are there drawings available for both tanks? No
9. Is the piping to be coated both externally and internally? Internally.
10. The pictures show a great deal of deterioration on the pipes, cleaning these can introduce a lot of turbidity to the tanks. This may pose a problem for filtration at your facility. It will have to be controlled.
11. Is the length of the pipes that extend out of the water to be coated? No
12. Will the tanks be off or on line during the work hours? No
13. Where is the hatch location on the #2 tank (25,000 Gal.)? on the side of the tank at the top of the tank next to the building.



Office of the Purchasing Director

Submit signed addendum #2 with your bid proposal.

Print Name

Signature

Company Name

Date