

# Addendum 2

City of Canton, Ohio  
Purchasing Department  
218 Cleveland Ave. SW, 6<sup>th</sup> floor  
Canton, Ohio 44702

CORNERSTONE PARKING GARAGE TENANT SPACE RENOVATIONS

**Item/Project**

Water Department

**Responsible Department**

January 24, 2019 at 2:00 PM local time

**Bids Due On or Before**

**Bid Proposal Submitted By:**

**Company Name**

**Street Address**

**City**

**State**

**Zip**

**Contact Person**

**Phone No.**

**Email Address**

ADDENDUM NO. 2

PROJECT: CITY OF CANTON  
WATER DEPARTMENT BILLING  
TENANT SPACE RENOVATIONS  
CORNERSTONE PARKING GARAGE  
306 SECOND STREET S.E., CANTON, OH

DATE: JANUARY 18, 2019

This addendum is a modification of the Bid Document for the construction of the above named project, and is hereby incorporated into and become a part of said Bid Document. It covers changes and clarification as follows:

REVISION/CLARIFICATION OF THE DRAWINGS & SPECIFICATIONS:

1. Product Approval Request: Leviton
  - a. Leviton shall be considered an approved equal to Hubbell contingent that Contractor include any additional items required for a complete installation.
2. Drawing E400: Tele-Data Plan
  - a. Any tele-data jacks not indicated to receive cabling are to be rough-in locations only
  - b. The face plate for the tele-data system is to be a 4-port plate with number of wired ports corresponding to number of cables, any unused ports are to be filled with filler plates
3. Drawing E402: Security Plan
  - a. Security Plan General Note Number 2 shall be omitted.  
DVR will be mounted in wall mounted rack and Access control has its own panel to contain equipment. 4-post rack is not required since wall mounted rack is being supplied by contractor.

END OF ADDENDUM NO. 2