

ADDENDUM NO. 1

DATE: August 23, 2019
TO: All Potential Bidders 
FROM: Julie Smith Maxwell, Procurement Specialist
SUBJECT: Addendum No. 1 – Tennis Court Maintenance Services
BIDS TO BE OPENED: September 12, 2019, at 11:00:00 a.m. Eastern Time

This addendum is being published to respond to a question asked by a potential bidder regarding the above-referenced Invitation to Bid. This addendum becomes a part of the Contract Document and modifies the original specifications as noted.

Question 1: The scope calls for a fabric system crack repair like Amor Crack or Rite Way. Will the City accept bids that use an acrylic patch binder for crack repair in lieu of a fabric system?

Response: Yes. The City will accept a substitution of an Acrylic patch binder for the repair of cracks up to once (1) inch in size. Any cracks larger than one (1) inch shall be repaired with a fabric system as originally specified.

END OF ADDENDUM NO. 1