 <p>CLAYTON COUNTY <b>Water</b> AUTHORITY</p> <p>1600 Battle Creek Road, Morrow, GA 30260</p>	<b>W.B. Casey WRRF and Shoal Creek WRF Secondary Launder Covers</b>	
	<b>ADDENDUM # 3</b>	
	DATE	Wednesday, June 26, 2024
	BID NUMBER	2024-WR-17
BID OPENING DATE	Tuesday, July 2, 2024 at 2:00 p.m. local time	
<b>ADDENDUM MUST BE SIGNED AND INCLUDED IN YOUR RESPONSE TO THE RFB.</b>		

**QUESTIONS:**

1. **I have received addendum 2 but never received addendum 1 and found out during the pre-bid meeting that the site visit date and time was changed. Can you schedule another site visit? I was not the only one who did not receive the first addendum.**

Answer: Addendum 1 was posted on June 5, 2024 on the [Georgia Procurement Registry](#), [Vendor Registry](#), and our website, at [www.ccwa.us](http://www.ccwa.us). Regretfully, an additional site visit will not be arranged prior to the Bid Opening scheduled at 2:00 p.m. on Tuesday, July 2, 2024.

2. **Does Clayton Co. absolutely REQUIRE the section from the scum baffle to the inner-most wall to be covered?**

Answer: The entire area must be covered.

- a. **If yes, then please be aware that the scum baffle scraper will need to be removed to permit coverage of this section.**

Answer: Scum baffle must not be removed.

- b. **If yes, then can anything “rest on”, or “be mounted to” the scum baffle, with the understanding that there is almost zero load on the scum baffle.**

Answer: Nothing can be mounted.

- c. **If not, will a vertical “plate” in front of the weir be acceptable to block sun from the weir?**


Answer: Possibly a drop plate.

- d. **Or do they even need anything at all?**

Answer: Something is needed.

3. **What is the minimum distance from the top of the outer wall to the sidewalk?**

Answer: No modification will be accepted.

 <p>CLAYTON COUNTY <b>Water</b> AUTHORITY</p> <p>1600 Battle Creek Road, Morrow, GA 30260</p>	<b>W.B. Casey WRRF and Shoal Creek WRF Secondary Launder Covers</b>	
	<b>ADDENDUM # 3</b>	
	DATE	Wednesday, June 26, 2024
	BID NUMBER	2024-WR-17
BID OPENING DATE	Tuesday, July 2, 2024 at 2:00 p.m. local time	
<b>ADDENDUM MUST BE SIGNED AND INCLUDED IN YOUR RESPONSE TO THE RFB.</b>		

**4. Can the steps be raised / modified for additional clearance to accommodate our tensioning ratchets?**

Answer: No modification will be accepted.

**5. Can they relocate the spray nozzles if we need them to?**

Answer: No relocation of spray nozzle.

**6. Due to the complexity involved in the design of the Shoal Creek Covers they will take longer to install. We request that the installation time given be increased form 30-45 days. Please let us know if this is acceptable?**

Answer: 30 days for Shoal Creek WRF.

**7. Being the Addendum 2 specifies maintenance free, can you specify the material to fiberglass or stainless-steel construction since these materials meet that standard?**

Answer: Any material is accepted.

**8. For the Shoal Creek WRF, Can you specify the width of the covers?**

Answer: Any width that fits will be accepted.

**9. Would it be possible to get a copy of the sign-in sheet from yesterday's site visit at the W.B. Casey WRRF?**


Answer: A copy of the Mandatory Site Visit Sign-In-Sheet is provided on page 4 of this Addendum.

**10. Do you have a list of plan holders/pre-bid meeting attendees for the project mentioned above? If so, can I have a copy sent to my email?**

Answer: A plan holders list is provided on page 5 of this Addendum.

**11. Is there a structural print showing launder width and weir wall thickness on the WB Casey tanks?**

Answer: Refer to the drawings provided with the [RFB documents](#).

 <p>CLAYTON COUNTY <b>Water</b> AUTHORITY</p> <p>1600 Battle Creek Road, Morrow, GA 30260</p>	<b>W.B. Casey WRRF and Shoal Creek WRF Secondary Launder Covers</b>	
	<b>ADDENDUM # 3</b>	
	DATE	Wednesday, June 26, 2024
	BID NUMBER	2024-WR-17
BID OPENING DATE	Tuesday, July 2, 2024 at 2:00 p.m. local time	
<b>ADDENDUM MUST BE SIGNED AND INCLUDED IN YOUR RESPONSE TO THE RFB.</b>		

**12. Please verify Div 4 Sec 2.2.B is a typo and it is ‘each cover’ rather than ‘each basin’.**

Answer: There is no external odor control.

**13. Please verify Div 4 Sec 2.2.E reference to odor control - whether this is part of an active scrubber system.**

Answer: Odor will be contained within covering.

<b>Acknowledgment of receipt of this addendum must be signed and included in your bid response.</b>	
COMPANY NAME	
SIGNATURE	
DATE	



1600 Battle Creek Road, Morrow, GA 30260

**W.B. Casey WRRF and Shoal Creek WRF  
Secondary Launder Covers**

**ADDENDUM # 3**

DATE	Wednesday, June 26, 2024
BID NUMBER	2024-WR-17
BID OPENING DATE	Tuesday, July 2, 2024 at 2:00 p.m. local time

**ADDENDUM MUST BE SIGNED AND INCLUDED IN YOUR RESPONSE TO THE RFB.**


**W.B. Casey WRRF and Shoal Creek WRF Secondary Launder Covers**

**Mandatory SITE VISITS - Sign-in Sheet**

- W.B. Casey Water Resource Recovery Facility (WRRF) located at 688 Flint River Road, Jonesboro, GA 30238
- Shoal Creek Water Reclamation Facility (WRF) located at 301 Hampton Road, Hampton, GA 30228

Tuesday, June 18, 2024 at 3:00 p.m. local time

COMPANY NAME	REPRESENTATIVE	PHONE NUMBER	EMAIL ADDRESS
CCWA	Hilda Flores	770-960-5223	<a href="mailto:Ccwa_procurement@ccwa.us">Ccwa_procurement@ccwa.us</a>
CCWA	Isabel Parrilla	770-960-5223	<a href="mailto:ccwa_slbe-program@ccwa.us">ccwa_slbe-program@ccwa.us</a>
CCWA	Kendra Stanciel	770-960-5223	<a href="mailto:ccwa-procurement@ccwa.us">ccwa-procurement@ccwa.us</a>
Sol Construction	MUZAFAR THAMEEM	979-985-7016	<a href="mailto:mthameem@solconstructionllc.com">mthameem@solconstructionllc.com</a>
CCWA	ROONEY WHITT	770-960-5223	<a href="mailto:ccwa-procurement@ccwa.us">ccwa-procurement@ccwa.us</a>
Cornerstone Mechanical	Audrey Irwin	404-944-2988	<a href="mailto:audrey@cornerstone-mechanical.com">audrey@cornerstone-mechanical.com</a>

 <p>CLAYTON COUNTY <b>Water</b> AUTHORITY</p> <p>1600 Battle Creek Road, Morrow, GA 30260</p>	<b>W.B. Casey WRRF and Shoal Creek WRF Secondary Launder Covers</b>	
	<b>ADDENDUM # 3</b>	
	DATE	Wednesday, June 26, 2024
	BID NUMBER	2024-WR-17
	BID OPENING DATE	Tuesday, July 2, 2024 at 2:00 p.m. local time
<b>ADDENDUM MUST BE SIGNED AND INCLUDED IN YOUR RESPONSE TO THE RFB.</b>		

**W.B. Casey WRRF and Shoal Creek WRF Secondary Launder Covers  
Vendor List**

Company	Representative	Phone	Email
Construct Connect	June Calago	323.602.5079 X 51076	<a href="mailto:June.Calago@ConstructConnect.com">June.Calago@ConstructConnect.com</a>
Cornerstone Mechanical	Andy Bramlett	(770) 742-3321	<a href="mailto:andy@cornerstone-mechanical.com">andy@cornerstone-mechanical.com</a>
Eco-Tech, Inc.	D. Scott Cockrell Tori West		<a href="mailto:SCockrell@eco-tech.net">SCockrell@eco-tech.net</a> ; <a href="mailto:Twest@eco-tech.net">Twest@eco-tech.net</a>
Environmental Instrumentation and Calibration Inc.	Josh Godbee	(478)-278-2659	<a href="mailto:joshgodbee@eicworks.com">joshgodbee@eicworks.com</a>
Good Lord's Mobile Welding Service, LLC	Carl Lomax	661-302-6128	<a href="mailto:carl_lomax@yahoo.com">carl_lomax@yahoo.com</a>
Heyward Incorporated Atlanta		(770) 286-1505	<a href="mailto:Ethan.Russo@heywardatlanta.com">Ethan.Russo@heywardatlanta.com</a>
IHC Construction Companies, LLC	Pieter Nielsen Ben Frank Kulling	404-497-7619	<a href="mailto:pnielsen@ihcconstruction.com">pnielsen@ihcconstruction.com</a> ; <a href="mailto:nkulling@ihcconstruction.com">nkulling@ihcconstruction.com</a>
Industrial and Environmental Concepts-	Michael Lever	952-829-0731	<a href="mailto:mlever@ieccovers.com">mlever@ieccovers.com</a>
NEFCO		561-775-9303	<a href="mailto:sales@nefco.us">sales@nefco.us</a>
NovaTech	Sandy Jenkins	315-813-7887	<a href="mailto:sjenkins@novatechnologiesgrp.com">sjenkins@novatechnologiesgrp.com</a>
Principle Environmental Inc.	Mary Watson	770.952.9444	<a href="mailto:marywatson@principleenvironmental.com">marywatson@principleenvironmental.com</a>
Protectolite Composites Inc	Charles Tomlinson	903.570.3459	<a href="mailto:ctomlinson@protectolite.com">ctomlinson@protectolite.com</a>
Razorback LLC	Kayla Kivinski	727.938.9500	<a href="mailto:kayla@razorbackllc.com">kayla@razorbackllc.com</a>
Sol Construction	Muzafar Thameem	949-985-7016	<a href="mailto:mthameem@solconstructionllc.com">mthameem@solconstructionllc.com</a>
Southern Water Technologies	Ben Frank	256-686-2682	<a href="mailto:ben@southernwater.com">ben@southernwater.com</a>
Templeton & Associates Engineering Sales	Jordan Longoria	470-345-4012	<a href="mailto:Jordan@templeton-associates.com">Jordan@templeton-associates.com</a>
The TDH Company	Allison Kulp	770-509-1808	<a href="mailto:akulp@tdhco.com">akulp@tdhco.com</a>
Utility Service Co., Inc.	Lisa Franklin	478.988.5266	<a href="mailto:bid@usgwater.com">bid@usgwater.com</a>
Warminster Fiberglass-	Bert Gardner	770-356-8722	<a href="mailto:bert@southernwater.com">bert@southernwater.com</a>
Waste Water Industrial Solutions	Virginia Murphy		<a href="mailto:vmurphy@wwisllc.com">vmurphy@wwisllc.com</a>
WesTech	Clint Curl	770-509-1808	<a href="mailto:ccurl@tdhco.com">ccurl@tdhco.com</a>