

ADDENDUM NO. 2
TO THE CONTRACT DOCUMENTS FOR
129 Tarboro Street
Structural Framing, Masonry Wall & Roof Construction
CITY OF WILSON, NORTH CAROLINA
NOVEMBER 20, 2023

To All Bidders:

This addendum is issued to modify or clarify the previously issued bid documents and/or given for informational purposes, and is herein made a part of the bid documents. This addendum must be acknowledged on the appropriate page of the contract Bid Form. Failure to acknowledge this addendum may subject the bidder to disqualification of his bid.

It is the responsibility of all bidders and all individual subcontractors to adhere to the following modifications, clarifications and/or information:

1. Base bid to include ½” cover board per manufacturer recommendation.
2. Add Alternate: Provide add to include R-30 insulation board. Minimum two (2) layers of 2.6” polyisocyanurate insulation board. Installation per manufacturer recommendations.
3. Membrane to be mechanically fastened in lieu of fully adhered.

END OF ADDENDUM NO. 2

Robert S. Bartlett, PE
Bartlett Engineering & Surveying, PC