

Sullivan Heights Chiller Replacement

January 5, 2023

ADDENDUM 1

The Bid Documents dated December 16, 2022 are amended as follows:

CLARIFICATION

- 1.) The question was asked is there glycol in the chiller loop.

Answer:

No, Sullivan county school's maintenance has confirmed that there is no glycol in the system.

PROJECT MANUAL

1. **Table of Contents**

- a. Insert the revised Table of Contents with revision 1 dated 1/5/23.

END OF ADDENDUM 1