

Addendum 1

City of Canton, Ohio
Purchasing Department
218 Cleveland Ave. SW, 4th floor
Canton, Ohio 44702

Pipe and Pipe Fittings

Item/Project

Water Department

Responsible Department

Monday, February 1, 2021 on or before 2:00 PM local time

Bids Due

Bid Proposal Submitted By:

Company Name

Street Address

City

State

Zip

Contact Person

Phone No.

Email Address

**Pipe and Pipe Fittings
Water Department**

Question 1:

We have questions regarding Section 38 Service Fittings pages 58 & 59. Many of the items do not designate if they are compression or flare. On past bids they had the Muller parts numbers the corresponded with each line item. Can you clarify?

Answer:

Section 38 for Service Fittings: If it states compression, it's compression. If it states copper, it's flare. Also, we do not include Mueller part numbers any longer. A Mueller part is not required.