

City of Havelock
Small Pavement Repairs
Addendum 1
December 8, 2016

The following question was received:

Question regarding the typical asphalt breakdown: The Bid Sheet specifies 2" or 3" Asphalt and aggregate, the detail drawing shows an 11" B-25.0B or B-25C Asphalt Base prior to installing the Surface Asphalt (2" or 3"). Can the City clarify this discrepancy?

Answer:

City Streets require 2-inches of asphalt.

State Roads require 3-inches of asphalt.

CITY OF HAVELOCK



Lee W. Tillman

Finance Director