

“City of Havelock,
Water leak at 326-A E. Main St Havelock, NC. 28532”

Addendum 1

August 3, 2023

Pre-Bid Meeting Questions

Attendance

- Step Construction
- Precision Earth and Pipe

Questions:

1. Will there be any time restrictions for the completion of this project?

Due to the size of the water leak, the City of Havelock will want this project to be prioritized and repaired as soon as possible upon award of the project.

2. Will the contractor be allowed to perform this work during nighttime hours?

No. There is a small possibility that the 10” water main will have to be isolated during the course of repair. The City of Havelock must have the capability of sending notifications and taking water samples, all of which must be done during normal business hours.

3. Can the 10” AC water main be isolated?

Yes, although the preference is to make a live line repair. During the course of this repair, if it is realized that the main must be isolated a City of Havelock representative will be available to isolate the 10” AC main water line.

4. As concrete or asphalt is damaged during the course of this project, will the contractor be responsible for replacement of the concrete or asphalt to the center of the road or only the area of disturbance?

Any asphalt that is damaged during the course of this job must be repaired. Saw cut straight and repaired within the area of disturbance before the completion of this project.