



OFFICE OF PROCUREMENT SERVICES
335 FOUR MILE ROAD
CONWAY, SC 29526-6005

AMENDMENT/ADDENDUM No. 3

Posting Date: Thursday, March 26, 2020

Solicitation Number: 1920-61VS

Description: North Myrtle Beach Middle School MAU & Duct Replacement

ADDENDA: Addenda shall be issued prior to the bid opening date and time for the purposes of modifying or interpreting the Contract Documents through additions, deletions, clarifications or corrections. No addendum shall be issued later than four (4) days prior to the bid opening date except to a) withdraw the Invitation for Bids, or b) to postpone the bid opening date and time. When an addendum is issued for the purposes of postponing the bid opening date and time, the addendum shall establish the new bid opening date and time no earlier than five (5) days after the addendum issue date. Addenda shall be posted on the on-line bidding source(s) stated in the Invitation for Bids. A Bidder shall acknowledge receipt of all addenda issued by identifying the addendum number and the date of issuance with the Bidder’s initials in the spaces provided on the Official Bid Form or the bid shall be found non-responsive in accordance with the District’s Procurement Code. If this solicitation is amended, then all terms and conditions which are not modified remain unchanged.

INTERPRETATIONS AND CLARIFICATIONS: Requests for additional information or questions regarding error, omission or clarification of any portion of the Bid Documents or the Contract Documents or any addendum, shall be submitted in writing to the District Bid Contact Person stated in the Invitation for Bids by e-mail or facsimile no later than five (5) days prior to the bid opening date and time unless an earlier date is stated on the Invitation for Bids or as may be amended. Any interpretations, corrections, or changes to the Bid Documents or the Contract Documents made in any other manner than by a written addendum shall not be binding, and Bidders shall not rely upon them. Any information given a prospective Bidder concerning a solicitation will be furnished promptly to all other prospective bidders as an addendum to the solicitation, if that information is necessary for submitting offers or if the lack of it would be prejudicial to other prospective bidders. See clause entitled “Bidder Representations.” We will not identify you in our answer to your question. The District seeks to permit maximum practicable competition. Bidders are urged to advise the Procurement Specialist – as soon as possible – regarding any aspect of this procurement, including any aspect of the solicitation that unnecessarily or inappropriately limits full and open competition.

Item # 1 HCS acknowledges that a crane will be needed to replace the MAU’s. Based on the site conditions this crane will need to travel over existing site work. The Contractor will be responsible for protecting the grassed areas as much as possible. Repair to the grassed areas will be at the **Contractor’s** cost. The Contractor shall make every effort to prevent damage to the hardscape, pavement and concrete curb and gutters, however, repairs to the damage of the hardscape, pavement and concrete curb and gutters will be at **Horry County Schools’** cost.

All other Work required in the Contract Documents to remain as described.

HORRY COUNTY SCHOOLS

By: _____
Robin B. Strickland, CPPB
Procurement Officer