



City of Carlsbad, New Mexico
RFP # 2020-23
Addendum 1

11/30/20

Addendum Notice – Reservoir #2 Tank Rehabilitation

The City of Carlsbad has added an additional bid alternate to the scope of work for this RFP. Please see Alternate 2 specifications on following page.

Thank you,
Matt Fletcher
Purchasing Manager
City of Carlsbad
575-234-7905

If you have any questions, please feel free to contact me at 575-234-7905 or email me at msfletcher@cityofcarlsbadnm.com.

Please return a signed copy of this addendum notice with your bid.

X _____
Name of Representative

Date: _____

CONCRETE STORAGE TANK REHABILITATION

Alternate 2

WALL REPAIRS

A. Surface Preparation

1. Prepare all interior vertical wall surfaces to be coated in accordance with the coating manufacturers recommendations.
2. Thoroughly clean all concrete interior wall surface to be coated to remove all dirt, dust and surface contaminants.
3. Interior wall surface of the tank interior shall be completely dry and have a minimum temperature of at least 5°F above the dew point at time of application of coating.
4. Moisture content of the concrete must be less than 5% as tested with a radio frequency moisture meter.
5. Apply a minimum 60 mil liner over the entire interior wall surface following all manufacturer's recommendations to provide a complete seamless liner.
6. Inspect and cure the interior wall coating in accordance with the manufacturer's recommendations.
7. Make repairs as required in accordance with the coating manufacturer's recommendations.