

 <p>CLAYTON COUNTY <b>Water</b> AUTHORITY</p> <p>1600 Battle Creek Road, Morrow, GA 30260</p>	<b>J. W. Smith Basin Rehabilitation</b>	
	<b>ADDENDUM 2</b>	
	DATE	Friday, August 23, 2019
	BID NUMBER	2019-WP-13
	BID OPENING DATE	Wednesday, September 4, 2019 at 2:30 P.M. local time
<b>ADDENDUM MUST BE SIGNED AND INCLUDED IN YOUR RESPONSE TO THE RFB.</b>		

## **QUESTIONS:**

- 1. In Division 4, Section 1, paragraph 1.2.G. it mentions work on “weak or suspect welds or bolts” are to be added to the bid. Is this work (labor and materials) to be a part of Item 4 on the Bid Form, Allowance?**

Answer: Yes.

- 2. Normally when these items get repainted, the squeegees which are attached to the bottom of the rakes are removed to coat are surfaces. Is the county or the contractor going to remove?**

Answer: The Contractor must remove.

- 3. Another question on the squeegees. Who will purchase new squeegees and install, the county or the contractor?**

Answer: CCWA will provide and install.

- 4. Schedule, when the date of Notice To Proceed is issued. Will the first basin already be drained/cleaned, or will we need to add that in schedule?**

Answer: Yes.

- 5. Schedule, it was mention at the Pre-Bid that the county needs two to three days to drain and clean each basin before the contractor can state our work. Is this time to be included in the completion of 120 days?**

Answer: Yes, this will be part of the 120 calendar days.

- 6. With advance notice, will the contractor be allowed to work on the weekends?**

Answer: No.

- 7. The used media from the sandblasting and existing paint chips. Are we to include removal from plant, hauling and disposal to a proper landfill?**

Answer: Yes, removing paint chips and sandblasting material is the Contractor's responsibility.

- 8. Can I get a copy of the pre-bid sign in sheet and update plan holders list?**

Answer: See pages 3 and 4 of this Addendum.



1600 Battle Creek Road, Morrow, GA 30260

## J. W. Smith Basin Rehabilitation

### ADDENDUM 2

DATE	Friday, August 23, 2019
BID NUMBER	2019-WP-13
BID OPENING DATE	Wednesday, September 4, 2019 at 2:30 P.M. local time

**ADDENDUM MUST BE SIGNED AND INCLUDED IN YOUR RESPONSE TO THE RFB.**

- 9. In Section 3: Bid Submittal Requirements Page 2-3.1 H. required to submit color charts showing the requested Colors, where is the requested colors listed?**

Answer: CCWA has requested colors.

- 10. In Section 3: Bid Submittal Requirements Page 2-3.2 M. required to submit sample warranty and manufacture’s certification, is the warranty requirement from the Manufacture or the Contractor and what Certification is need from Manufacture?**

Answer: The warranty/certification is supplied by the manufacturer as well as confirmation that the contractor is approved to install coating system specified.

- 11. In Section 3: Bid Submittal Requirements Page 2-3.1 H. required to submit published catalog data showing that the protective coating products that will be provided meet or exceed material and design specifications/standards, is meeting the AWWA and NSF the only design specifications/standard Required?**

Answer: Meeting specifications/standards of AWWA and NSF along with the details of manufacturer’s specification of product is required.

***Acknowledgment of receipt of this addendum must be signed and included in your bid response.***

COMPANY NAME	
SIGNATURE	
DATE	



1600 Battle Creek Road, Morrow, GA 30260

# J. W. Smith Basin Rehabilitation

## ADDENDUM 2

DATE	Friday, August 23, 2019
BID NUMBER	2019-WP-13
BID OPENING DATE	Wednesday, September 4, 2019 at 2:30 P.M. local time

**ADDENDUM MUST BE SIGNED AND INCLUDED IN YOUR RESPONSE TO THE RFB.**

Clayton County Water Authority

### Non-Mandatory Pre-Bid Meeting and Site Visit

Wednesday, August 14, 2019 at 2:30 P.M. (local time)

Department: WATER PRODUCTION

Bid Title: J.W. SMITH BASIN REHABILITATION

Bid Date and Time: Wednesday, September 4, 2019 at 2:30 P.M. (local time)

Page 1 of 2

COMPANY NAME	REPRESENTATIVE	PHONE NUMBER	EMAIL ADDRESS
LLAMAS CONCRETE	ROBERT STARK	41210-3323	smoky@llamasconcrete.com
Willow Construction	Alan Gravel	770-222-1555	agravel@willowcon.com
CCWA	Kendra Staniel		ccwa_procurement@ccwa.us
CCWA	Stephen Tarpley		
CCWA	Karen Riser		
CCWA	Hilda Flores		
CCWA	Kathy Bogaert		

Clayton County Water Authority

### Non-Mandatory Pre-Bid Meeting and Site Visit

Wednesday, August 14, 2019 at 2:30 P.M. (local time)

Department: WATER PRODUCTION

Bid Title: J.W. SMITH BASIN REHABILITATION

Bid Date and Time: Wednesday, September 4, 2019 at 2:30 P.M. (local time)

Page 2 of 2

COMPANY NAME	REPRESENTATIVE	PHONE NUMBER	EMAIL ADDRESS
Contessa Construction	Angela Ellinwood	404-547-0443	angela@contessa-cs.com
MOPAC	Gene Dobbins	404 604 0343	gdobbins@mopac.biz



1600 Battle Creek Road, Morrow, GA 30260

## J. W. Smith Basin Rehabilitation

### ADDENDUM 2

DATE	Friday, August 23, 2019
BID NUMBER	2019-WP-13
BID OPENING DATE	Wednesday, September 4, 2019 at 2:30 P.M. local time

**ADDENDUM MUST BE SIGNED AND INCLUDED IN YOUR RESPONSE TO THE RFB.**

J.W. Smith Basin Rehabilitation					
VENDOR LIST					
Vendor Name	Address	City, State, Zip	Contact Person	Phone #	Email Address
ACA & Twins Painting Company, LLC	1333 Muirforest Way	Stone Mountain GA 30086	Malachi Smith	678-462-3944	businesschi@yahoo.com
Airco, Inc.	129 Pine Road	Newnan, Ga. 30263		770-683-2786	<a href="mailto:jwaincott@aircocorp.com">jwaincott@aircocorp.com</a>
All American Markets Inc., dba MOPAC	836 Joseph Lowery Blvd.	Atlanta GA	Gail M. Morris	404-872-0434	mopac@mopac.biz
Atlanta Aviation Consultants			Rundy Tatum	404 808 3136	rundy.tatum@atlantaaviationconsultants.com
Cherry Innovative Painting Co. Inc.	5289 Winslow Crossing Nor	Lithonia GA 30038	James Cherry	770-981-6511	cherrypaintingcoinc@netzero.net
Commercial Painters 360, LLC			Tresia W. Burks	404-399-9999	commercialpainters360@gmail.com
Contessa Construction			Angela Ellinwood	404-547-0443	<a href="mailto:angela@contessa-cs.com">angela@contessa-cs.com</a>
CTR Coatings			Lanny Barker		<a href="mailto:lanny@ctrcoatings.com">lanny@ctrcoatings.com</a>
DACA	6550 McDonough Drive	Norcross, Ga. 30093		888-451-6433	<a href="mailto:JJunot@dacaspecialtyervices.com">JJunot@dacaspecialtyervices.com</a>
Dodge Data & Analytics			Rechie		<a href="mailto:notify@quickbase.com">notify@quickbase.com</a>
First Infinity Construction, Inc.	1527 Nabell Avenue	East Point GA	Nicole J. Queen	404-763-5963	nicholej@firstinfinity.com
Haren Construction Company, Inc.	1715 Highway 411 North	Etowah, TN 37331	Cynthia A. Osborne	423-263-5561	<a href="mailto:cosborne@harenconstruction.com">cosborne@harenconstruction.com</a>
Illuminis Contracting Services, Inc.	1633 Clifton Downs Ct.	Kennesaw GA	Timmy Sungsoo Kim	770-455-6081	tomyumkim@yahoo.com
Imigiz Enterprises, LLC	1211 Ling Way	Austell GA 30168	Phillip Barnett	678-754-0435	imigiz2004@aol.com
Interior Specifics Inc.	1809 Orange Grove Pl.	Austell GA 30106	Kenneth Carter	678-576-5210	Kenneycarter3@yahoo.com
Llamas Coatings, Inc.	2210 River View Road	Atlanta, Ga. 30339		404-210-3323	<a href="mailto:smoky@llamascoatings.com">smoky@llamascoatings.com</a>
MOPAC			Gene Dobbins	404-606-0393	<a href="mailto:gddobbins@mopac.biz">gddobbins@mopac.biz</a>
MSF Construction, LLC.	1208 Tree Creek Pkwy	Lawrenceville GA 30043	Monica Nunez	770-873-7881	mnunez@msfcg.com
Ochoa General Interiors, Inc.	3145 Dogwood Dr. Ste A	Hapeville GA 30354	Jose Ochoa	404-254-0716	jose@ochoaconstruction.com
PC Construction Company	193 Tilley Drive	South Burlington, VT 05403	Alan Parent	802.651.1375	<a href="mailto:aparent@pcconstruction.com">aparent@pcconstruction.com</a>
Premier Painting Service, LLC	694 Shore View Drive	Lithonia GA 30058	Lucius Scott, Jr.	678-861-9438	lscottjr@premierpaintingsvc.com
Raker Construction Company, L.L.C	401 Butler Industrial Drive	Dallas GA	Sharon Rakestraw-Morgan	770-445-1191	sharon@rakerco.com
Revere	3810 Drane Field Rd Ste 7	Lakeland FL 33811	Clare Connelly	(863) 940-5120	<a href="mailto:cconnelly@reverecontrol.com">cconnelly@reverecontrol.com</a>
Steeple Enterprises, LLC	3700 River Lake Shore	Ellenwood GA 30294	Julie Patterson	678-232-4298	jpatterson@steepleenterprisesllc.com
The Paint Doctor, Inc.	694 Bryan Street	Atlanta GA 30312	Archie Deese	404-524-8283	archieeese@atlantaspaintdoctor.com
Turcotte, LLC	1415 Avery Rd.	Canton GA 30115	Lisa Turcotte	678-699-0890	turcottellc@gmail.com
Uesi			Ogilvie, Jason		<a href="mailto:joilvie@uesi.com">joilvie@uesi.com</a>
Willow Construction, Inc.			Alan Gravel	770-222-1555	<a href="mailto:agravel@wilocon.com">agravel@wilocon.com</a>
Wilson Welding Services, Inc.	2939 Snapfinger Road	Decatur, Ga. 30034		770-981-3535	<a href="mailto:jackwilson@wws54.com">jackwilson@wws54.com</a>