


ADDENDUM NO. 1

DATE: December 3, 2018
TO: All Proposers 
FROM: Julie Smith Maxwell, Procurement Specialist
SUBJECT: Addendum No. 1 – Motorized Exhibit Hall Gate
PROPOSALS DUE: December 13, 2018, at 11:00:00 a.m. Eastern Time

This addendum is being published to respond to questions asked by a potential proposer regarding the above-referenced Request for Proposals. This addendum becomes a part of the Contract Document and modifies the original specifications as noted.

Question 1: Will the City or the vendor be responsible for the “finish” (i.e. prime, paint, etc.) for the tube that will be visible along the wall?

Response: Vendor will provide a turnkey product to include the finish. The City will provide a paint swatch, if desired, for matching color.

Question 2: There will likely be a gap between the wall and the gate assembly due to the overhang in the ceiling. How would the City like this gap to be addressed?

Response: The City would like the block cut to reduce the size of the gap between the wall and the pole. Caulk the remaining gap between the pole and the wall.

Question 3: Are we permitted to drive our truck onto the floor during the installation process?

Response: Yes.

Question 4: Do the keys need to match the systems already in place?

Response: Yes.

Question 5: Will the City or the vendor be responsible for the conduit?

Response: The vendor.

END OF ADDENDUM NO. 1