

ADDENDUM NO. 1

DATE: December 7, 2022

TO: All Potential Bidders

FROM: Penny Owens, Purchasing Agent, City of Knoxville

SUBJECT: Addendum No. 1 – CIPP IV Stormwater Infrastructure Rehabilitation Project

BIDS TO BE OPENED: January 3, 2023, at 11:00:00 a.m. (Eastern Time)

This addendum is being published to make changes to respond to questions that the City has received from potential bidders. This addendum becomes a part of the contract documents and amends the specifications as detailed below.

Questions Received:

Question #1: Before I submit formal questions and order plans would you be able to tell the diameter of the 1500' of pipe to be lined?

Response #1: The liner schedule detailing all diameters and lengths of the pipe segments to be rehabilitated can be found on Sheet C0.2 – General Notes of the construction plans.

Question #2: Please review the attached documents and advise if you will allow Thermoform Liner as an alternative to CIPP.

Response #2: This project only specifies cured-in-place pipe and on certain pipe segments, geopolymer lining, as a method of rehabilitation. Alternative methods including Thermoform PVC will not be considered for this particular project.

END OF ADDENDUM NO. 1