

ADDENDUM NO. 2

DATE: December 12, 2022

TO: All Potential Bidders

FROM: Penny Owens, Purchasing Agent, City of Knoxville

SUBJECT: Addendum No. 2 – CIPP IV Stormwater Infrastructure Rehabilitation Project

BIDS TO BE OPENED: January 3, 2023, at 11:00:00 a.m. (Eastern Time)

This addendum is being published to respond to questions that the City has received from potential bidders. This addendum becomes a part of the contract documents and revises the specifications as detailed below.

Questions Received:

Question #1: Would shotcrete be an acceptable alternative lining method instead of the CIPP for the larger pipes?

Response #1: No, shotcrete is not an acceptable alternative lining method for this project.

Question #2: Are you allowing UV Cure CIPP? It is a much stronger product without the contaminated water used in water cured lining.

Response #2: UV curing is an acceptable alternative to water curing for this project. However, the contractor will have to provide liner thickness design calculations sealed by a Tennessee registered professional engineer as part of the preconstruction submittal material for approval by the city of Knoxville Engineering Department.

Question # 3: The invitation to bid references a Drug Free affidavit but we cannot find that in the document.

Response #3: Attached please find a revised Submission Affidavits and Certifications form BD-28 through BD-30 which hereby replaces the previous form.

END OF ADDENDUM NO. 2