

**PURCHASING DIVISION**

901 Broadway, N.E. • Knoxville, TN 37917-6699
865.403.1133 • Fax 865.594.8858
800.848.0298 (Tennessee Relay Center)
Email: purchasing@kcdc.org
<http://www.kcdc.org/en/DoingBusiness.aspx>

Addendum

SOLICITATION NAME	Repairs to 357 McConnell Street Q1501	ADDENDUM NUMBER	1	DATE	09-09-14
--------------------------	---------------------------------------	------------------------	---	-------------	----------

KCDC is providing this addendum to answer questions that have been raised about this solicitation. To aid in readability, the questions are in black and the answers are in **bold** and the answers follow immediately below.

Q1	Is there asbestos flooring on the ground level?
	There is asbestos containing mastic and the vendor will have to handle it accordingly. The vendor needs to verify the tile.
Q2	Describe the wiring work that will need to be performed.
	All wiring in the living room and up the steps to the second floor will have to be replaced. The vendor will replace: <ul style="list-style-type: none">• Four receptacles• Two 3-way switches• Two smoke detectors• 1,250 feet of wiring• The one thermostat that controls the heater below the window. The vendor will also check the heater for damage.
Q3	What brand appliances are to be used?
	Match the existing brands and models. The Senior Asset Manager can give you guidance.