Village of Addison Purchasing Department 1 Friendship Plaza Addison, IL 60101

ADDENDUM NO. 1

SCADA Improvements at the North Wastewater Treatment Plant

RETURN WITH RFP

January 31, 2024

TO: ALL PROSPECTIVE BIDDERS

FROM: Ewa Adamow, Purchasing Agent

Correction #1

SPECIFICATION SECTION 26 09 00-CONTROLS AND INSTRUMENTATION, PARAGRAPH 2.04.C.1.b:

Delete "b. 256 controller connections" in its entirety.

Correction #2

SPECIFICATION SECTION 26 09 00-CONTROLS AND INSTRUMENTATION, PARAGRAPH 3.02.A:

Change "Replace stainless steel plate that the OIP is mounted to with new stainless steel plate to cover opening in panel." to "Replace stainless steel plate that the OIP is mounted to with new stainless steel, aluminum, or painted steel plate to cover opening in panel. New plate shall have squared corners, beveled edges, and be affixed with countersunk bolts."

Correction #3

SPECIFICATION SECTION 26 09 90-I/O LISTING, PAGE 6, REMOTE I/O PANEL STB (RIO-STB):


Replace "FROM BLOWER CONTROL PANEL" with "FROM AERATION BLOWER HIGH PRESSURE SWITCH" in the comments column for the Aeration Blower Fail signal.

Correction #4

DRAWING 20-E1.01:

Replace entire sheet with the attached revised sheet.

Dated at Joliet, Illinois January 31, 2024



STRAND ASSOCIATES, INC.[®] IDFPR No. 184-001273 1170 South Houbolt Road Joliet, IL 60431

Please sign below and return with your RFP documents.

Signature of Bidder_____

