



PURCHASING DIVISION

901 Broadway, N.E. • Knoxville, TN 37917-6699
 865.403.1133 • Fax 865.594.8858
 800.848.0298 (Tennessee Relay Center)
 Email: purchasing@kcdc.org
<http://www.kcdc.org/en/DoingBusiness.aspx>

Addendum

SOLICITATION NAME	ADDENDUM NUMBER	DATE
Fire Extinguisher Services Q1429	1	02-24-14

KCDC is providing this addendum to answer questions that have been raised about this solicitation. To aid in readability, the questions are in black and the answers are in **bold** and the answers follow immediately below.

Q1	Is this request for monthly inspections on the fire extinguishers or for an annual inspection as required by NFPA?
	Annual Inspections.
Q2	Stated on page 2 section 1.g, the quote specifies fire extinguishers that have outdated cylinders are to be replaced. Cylinders usually are good for 12 years. Your line items for price quotes do not show a quote request for a 6 year maintenance for your extinguishers. If the extinguisher is over six years old but less than 12 years or it has been six years since the last maintenance/hydro-test, NFPA requires a six year inspection, which in a more detailed and more time consuming inspection than an annual inspection. Is it acceptable to quote the six year maintenance on one of the "Other" lines
	Yes vendors may quote this option on one of the "Other" lines.