



WILLIAMSON COUNTY GOVERNMENT

September 4, 2020

Addendum # 1

Parks Pool Re-plaster- Franklin and Longview

Bid Date September 29, 2020, 2:00 p.m.

Please add to the specifications:

Instructions for Bonding Agent and Plaster by CL Industries must be followed.
After Pool is filled with Water, Contractor must immediately balance chemicals (this is part of the instructions by CL Industries).

Please make the following change to the specification:

The specifications reference 4x4 tiles, this is not correct, it should be 6x6 tiles. There are 6x6 tiles currently in place and these should be replaced with 6x6 tiles. Please change any reference for a 4x4 tile to a 6x6 tile.

