

SUPPLEMENTAL INFORMATION
ADDENDUM NO. 2

PROJECT: RFP 21-006
Fuel Management System

CONTACT: Alison Bruton, Purchasing Tech.
912-754-2159 abruton@effinghamcounty.org

DATE ISSUED: January 8, 2021

RFP 21-006 – Fuel Management System dated December 8, 2020 is hereby amended as noted herein: BIDDER TO ACKNOWLEDGE RECEIPT OF ADDENDUM BY SIGNING ON THE SIGNATURE LINE BELOW AND INCLUDING A COPY WITH SUBMITTED BID. FAILURE TO DO SO MAY, AT THE OWNER’S DISCRETION, SUBJECT THE BIDDER TO DISQUALIFICATION

- 1) QUESTION: Which of the following should the tank monitoring system provide?
- Real-time tank levels and/or volumes.
 - Tank data history / trending.
 - Tank Alarms / Notifications (gauge offline, low level, re-order point, etc.)
- ANSWER: Tank Alarms / Notifications (gauge offline, low level, re-order point, etc.)
- 2) QUESTION: Please confirm conduit paths are available for following:
1. Dispensers to pedestals.
 2. Between pedestals.
 3. Pedestals to TLS300.
 4. Does conduit go all the way to the TLS unit or just to the building housing the TLS?
- ANSWER:
1. Yes
 2. Yes
 3. Yes
 4. Just to Building

Addendum No.2
RFP 21-006 – Fuel Management System

All other terms and conditions in RFP 21-006 remain unchanged.

Effingham County reserves the right to reject any and all proposals, to waive any technicalities or irregularities and to award the offer based upon the most responsive, responsible submission.

Please sign receipt of this Addendum No. 2 below:

Print Name

Signature

Date

END OF ADDENDUM NO. 2