

ADDENDUM NO. 1
TO THE CONTRACT DOCUMENTS FOR
LODGE STREET PARKING LOT
CITY OF WILSON, NORTH CAROLINA
MAY 24, 2022

To All Bidders:

This addendum is issued to modify or clarify the previously issued bid documents and/or given for informational purposes and is herein made a part of the bid documents. This addendum must be acknowledged on page 13 of the contract Bid Form. Failure to acknowledge this addendum may subject the bidder to disqualification of his bid.

It is the responsibility of all bidders and all individual subcontractors to adhere to the following modifications, clarifications and/or information:

1. Bidders to utilize updated Official Bid Proposal Form labeled Addendum No. 1, dated 5/24/2022. Added bid items:
 - Thermo Pavement Markings Symbols (arrows, HC, stop bars, etc.)
 - Junction Manhole Replacement at intersection of Lodge and Barnes
2. Clarification for "Traffic Control" bid item; The City of Wilson will take care of any street closures required to complete the work. Contractor to provide any incidental traffic control and coordination.
3. Clarification for "Demo" bid item; Some demolition items shown on the Bid Set have already been removed. Contractor shall provide whatever demolition and removal as necessary to complete the project.
4. Clarification for "Signage" bid item; Line items shall include 4 stop signs and all required ADA parking signs.
5. All RCP is Class III.
6. Clarification for "Asphalt" bid item; 3" S9.5B(2-lifts) is correct, the detail provided is incorrect.

END OF ADDENDUM NO. 1

Robert S. Bartlett, PE
Bartlett Engineering & Surveying, PC