



Jackson County Board of Commissioners

67 Athens Street
Jefferson, Georgia 30549
Phone: (706) 367-6309
Fax: (706) 708-2505
Email: myarbrough@jacksoncountygov.com

Date: April 26, 2021

To: Generator Companies

From: Myrna Yarbrough, Purchasing Manager

RE: Addendum 1 to Jackson County ITB 210009, Furnish and Install Generator, Jackson County Correctional Institute

1. Addendum 1 is hereby issued to provide sign in sheet of mandatory prebid meeting and to answer questions and provide clarifications, per attached.
2. All other terms and conditions in ITB 210009 remain unchanged.
3. Any inquiries concerning Addendum 1 should be made to Myrna Yarbrough, Purchasing Manager, (706) 367-6309 or via email at myarbrough@jacksoncountygov.com
4. Jackson County reserves the right to reject any and all proposals, to waive any technicalities or irregularities and to award the offer based upon the most responsive, responsible submission.
5. Bidders must acknowledge receipt of addenda, by either signing and attaching this copy, or by writing "Acknowledge Addenda #1" at bottom of the proposal.
6. Cellphone policy as requested by local bldg manager.
7. Contractors will be escorted + supervised by Correctional Institute police.
8. Preferred work hours 8AM-4PM. Contractor could start earlier, 6am if requested by contractor and Correctional Institute bldg manger approval. 7AM-8AM and 4PM-5PM not available for check-in or check-out.
9. As indicated during pre-bid
 - Facility shall be maintained operational all the time (if required by contractor MOP, provide temporary wiring + temporary power).
 - Wiring for new UPS receptacles + lighting could be installed thru the attic (preferred route).

- Mechanical room – new transformer + panel shall be installed on the west wall/ space available on the west wall.
 - All equipment layout + wiring route shall be approved by Correctional Institute building manager (set up meeting with Correctional Institute building manager before commencing work to get approval for contractors' proposed equipment layout + wiring route).
 - Five Years Warranty and 5-years full-service maintenance for the entire generator system should be included in the bid price.
 - Include cost to relocate existing generator to EMA Department, 368 Curtis Spence Dr., Jefferson, GA.
10. Inventory of all tools is required before entrance into the facility. All tools on inventory list must be accounted for before exiting the facility. No job material or tools shall be left unattended at any time.

Furnish & Install Generator, JCCI 210009

Pre Bid Meeting: April 23, 2021 at 10:00 AM

Company Name	Representative	Telephone	E Mail
J&T Service Center Inc.	Jared Fleming	706 339 8774	Ted@jtservicecenter.com
Anderson Power Services	Dustin Strickman	770 480 8089	Dustin@andersonpowerservices.com
Critical Components Inc	Robney Speight	404-402-9209	Robney@CITech
Critical Power Resiliency LLC	Drake Young	678 634 3605	dyoung@resiliency.com
MITCH HASKELL INC	ENG GRADUP	678 576 6816	MITCH@ENG-GRADUP.COM