

City of Spartanburg

Procurement and Property Division

Post Office Drawer 1749, SC 29304-1749 P (864)-596-2049 F (864) 596-2365

ADDENDUM # 1

Spartanburg Downtown Airport T-Hangar

500 Ammon Road

Question/Answers

March 3, 2017

Questions:

1. What will the eave height of the new hanger be?

Answer:

The eave height is a minimum of approximately 17'5" +/-

The minimum door height is a minimum of 14' +/-

Questions:

2. Where do I find the requirements for paving on the project, depth, width, length and sketch of how to install.

Answer:

The information requested is on the revised asphalt drawing attached and on the website.