

PUBLIC WORKS BUILDING NEW FUEL STATION

INVITATION TO BID – REQUISITION NO. 2020-0625

ADDENDUM NO. ONE (1) – DATED JUNE 9, 2020

The information given in this addendum is in addition to or supersedes conflicting information to the invitation to bid and is hereby made a part of the request.

Question #1: Are engineered stamped drawings required for the fuel tank foundation?

Answer: No, engineered stamped drawings are not required by the City's Building Department for the fuel tank foundation.

Question #2: What size submersible pump motors will be required?

Answer: 3/4 HP

Question #3: Is the exterior coating of the fuel tank to be white epoxy?

Answer: Yes, the exterior coating of the fuel tank shall be white epoxy.

Question #4: Will the site be at sub-grade elevation?

Answer: The site will be at sub-grade elevation \pm 0.1 foot.

Please be sure to acknowledge receipt of this addendum on your bid form.