

ADDENDUM NO. 1

DATE OF ISSUANCE:	February 1, 2022
PROJECT:	Portage – Northern High School – Campus Storage Barns 1000 Idaho Avenue Portage, MI 49024
OWNER:	Owner's Name
ARCHITECT'S PROJECT NO.:	20-200.00
ORIGINAL BID ISSUE DATE:	January 20, 2022

SCOPE OF WORK

This Addendum includes changes to, or clarifications of, the original Bidding Documents and any previously issued addenda, and shall be included in the Bid. All of these Addendum items form a part of the Contract Documents. The Bidder shall acknowledge receipt of this Addendum in the appropriate space provided on the Bid Form. Failure to do so may result in disqualification of the Bid.

DOCUMENTS INCLUDED IN THIS ADDENDUM

This Addendum includes **[2] two** pages of text and the following documents:

- Bidding Documents: **none.**
- Contract Conditions: **none.**
- Specification Sections: **none.**
- Drawings: **none.**

CHANGES TO PREVIOUSLY ISSUED ADDENDA

None.

CHANGES TO BIDDING REQUIREMENTS

None.

CHANGES TO CONTRACT CONDITIONS

None.

CHANGES TO SPECIFICATIONS

ADD-1 Item No. S-1 - 08 1113 Hollow Metal Doors and Frames

NuPlank aluminum doors and frames are considered an equal to the doors specified in section 08 1113.

The bidder has the option to provide NuPlank Aluminum doors (info@nuplank.com) or hollow metal doors as specified. Note: hardware changes required for the aluminum doors shall also be considered and properly bid by the contractor.

ADD-1 Item No. S-2 - Update Door Hardware

Refer to Specification Section 08 7100 Door Hardware, update schedule:

Hardware Group No. 1.0

Each To Have:

Qty		Description	Catalog Number	Finish	Mfr
3	EA	HINGE	5BB1HW 4.5 X 4.5 NRP	630	IVE
1	EA	MORTISED LOCKSET	8205, LNB	626	SAR
1	EA	CYLINDER	KEYED TO AND MATCH EXISTING KEY SYSTEM	626	SAR
1	EA	SURFACE CLOSER	Norton 7500	689	NOR
1	EA	KICK PLATE	8400 24" X 2" LDW B-CS	630	IVE
1	EA	RAIN DRIP	142AA	AA	ZER
1	EA	GASKETING	429AA	AA	ZER
1	EA	DOOR SWEEP	8198AA	AA	ZER
1	EA	THRESHOLD	655A	A	ZER

CHANGES TO DRAWINGS

ADD-1 Item No. D-1 - Update Door Schedule

Refer to Sheet: AA 101 – Door Schedule

Omit doors 104A and 104B Referenced on the schedule on this sheet, those are for building B and show up properly on sheet AB 101.

END OF ADDENDUM.