

# Addendum 1

**City of Canton, Ohio**  
Purchasing Department  
218 Cleveland Ave. SW, 4<sup>th</sup> floor  
Canton, Ohio 44702

Crenshaw Park Outdoor Shelter

---

**Item/Project**

Park Department

---

**Responsible Department**

2:00:00 PM, 1/10/2024

---

**Bids Due On or Before**

## **Bid Proposal Submitted By:**

---

**Company Name**

---

**Street Address**

---

**City**

**State**

**Zip**

---

**Contact Person**

**Phone No.**

**Email Address**

**Question:**

I am trying to quote the 2-compartment sink and the front concession counter in room 100 Concessions under Section 11400 Stainless Steel Counters. According to elevations CE-1/A-3.1 and CE-2/A-3.1, these units are to have laminated. Please clarify if Section 11400 is to provide just the stainless steel countertops or the entire cabinet. If the entire cabinet is to be provided, please provide information regarding the laminate required for these units as nothing is called out in Section 11400.

**Answer:**

Counters are to be stainless steel per specification section 12 36 16 Stainless Steel Counters. Casework is to be laminate per specification section SEC. 06 41 16 Architectural Casework.