



WILLIAMSON COUNTY GOVERNMENT

December 18, 2018

Addendum #1
Williamson County Franklin Recreation Complex Pool Re-Plastering
Bid opens January 15, 2019, 2:00 p.m.

We have received the following questions/comments:

The specifications that you are calling for using Krystal Krete -Blue Quartz as the surface prep material. Please know that is a finish material and not a prep material.

The other finish material that is being specified (white Portland and marble dust-pool mix). Basically there are two finish materials specified and the pricing will be significantly different between the two. Which finish do you wish to use Krystal Krete or field blended Marcite? The prep material is most likely bond coat or scratch coat.

Materials: Pre-plaster Bonding Agent – “Permacote” by CL Industries
Plaster: Krystalkrete, by CL Industries

Installation:
Plaster: Pre-Plaster Bonding Agent shall be “Permacote”
Finish Plaster Coat: Krystalkrete, by CL Industries

