



Dinwiddie County Procurement

14010 Boydton Plank Road

Dinwiddie, VA 23841

Phone: (804) 469-4500, Option 1, Ext 2150

E-Mail: hcasey@dinwiddieva.us

www.dinwiddieva.us/purchasing

ADDENDUM #2

Date: March 18, 2024

Invitation For Bids # 24-022324

HVAC Rooftop Unit Replacement, Pamplin Building

Deadline: March 21, 2024 at 2 p.m. EST

TO ALL POTENTIAL BIDDERS:

The following information is being provided for purposes of clarification or in response to questions received from potential bidders. In the event that any of these specifications conflict with previous specifications, the specifications in this addendum shall control. Prepare your bids accordingly:

1. Pre-bid attendance sheet is attached.
2. Even though federal terms and conditions do apply to this project, Davis-Bacon Act does not apply.
3. Contractor will need to apply for County permits but they will be free of charge.
4. Mobilization of the old and new units will need to be scheduled on the weekends or days when School offices are closed.
5. Contractor's staff may use the restrooms in the Pamplin building; however, cleanliness is a requirement. No mud or dirt shall be tracked in the building.
6. If the units can be placed on the County's trailer, the County will dispose of them. If not the Contractor must do so. Contractor must dispose of refrigerants.
7. Refrigerant pipes shall be wrapped in aluminum jacket.
- 8. Contractors shall include equipment specifications/submittals with their bids.**

Note: A signed acknowledgement of this addendum must be received by this office prior to the due date and time, or must be attached to your bid. Signature on this addendum does not constitute signature on the original bid document. The original bid document must also be signed per bid instructions.

Company Name: _____

Signature: _____

Type/Print Name: _____

Title: _____

Date: _____

Mandatory Pre-Bid
IFB #24-022324
HVAC Rooftop Unit Replacement, Pamplin Building
Tuesday, March 12, 2024 at 9 a.m.

Company Name/Contact	Address	Phone	Email
Climate Mechanical Cameron Brown	Central VA	(804) 718-9863	info@climatemechanical.com
Colonial Webb Brandon Hornberger	Central VA	(804) 399-8689	Brandon.hornberger@colonialwebb.com
Moores Electric & Mechanical Construction, Inc. David Maddox	101 Edgewood Ave Altavista, VA 24517	(434) 369-4374 (434) 309-2454	kdoss@mooreselectric.com dmaddox@mooreselectric.com
Aces Roanoke Terry Johnston	4358 Starkey Rd, Suite B Roanoke, VA 24018	(540) 793-4808	tjohnston@havtech.com
WACO Tim Durrett	5450 Lewis Road Sandston, VA	(804) 499-9052	tdurrett@wacoinc.net
Old Dominion Mechanical John Bailey	800 W. Leigh Street Richmond, VA 23220	(804) 513-1487	jbailey@odmva.com
Chesapeake Controls Health Kearney	3819 Holland Blvd Chesapeake, VA 23323	(757) 344-9458	Heath@chesapeakecontrols.com

Warwick Mechanical Larry Worrell Rick Hines	11048 Warwick Blvd Newport News, VA 23601	(757) 879-8917 (757) 879-8971	worrell@wphcorp.com rhines@wphcorp.com
Lipscomb Electric & Contracting	206 Timbercreek Farm Drive Farmville, VA 23901	(804) 347-8880	rr.lipscomb@live.com