

**ADDENDUM NUMBER TWO**  
**REPLACEMENT ROOFING SYSTEMS FOR**  
**CARVER YFD CENTER**  
**600 N. ORCHARD KNOB ROAD**  
**FOR THE CITY OF CHATTANOOGA, TENNESSEE**  
**Contract Number Y-17-007**

THE HEADING ON ADDENDUM 1 INCORRECTLY LISTED THE SHEPHERD YFD CENTER LOCATION AND PROJECT NUMBER, RATHER THAN THE CARVER YFD CENTER. THE TEXT WITHIN THE BODY OF THE ADDENDUM CORRECTLY LISTS THE CARVER YFD CANETER AS THE LOCATION OF THE PRE-BID MEETING. THE CITY APPOLIGIZES FOR THE ERROR.

**A QUESTION HAS BEEN RECEIVED REGARDING THE HVAC WORK AT CARVER YFD CENTER.**

**Question:** Just to make sure I understood correctly, on Carver, the new HVAC units will be coordinated with the roof project correct? I went over this last night and no questions to submit came up.

**Answer:** As much as is possible, the City would like to coordinate the removal and installation of the new HVAC units on Area D with the installation of the roof. It is not intended that any of the work related to the new HVAC units, including removal, new curbing, curb height adjustment, or electrical work, be the part of the roofing contract.

Since there seems to be a problem with the curbing as installed on Area B, we would like the coordination with the HVAC contractor to be such that the roofing contractor provides **information** on proper curb heights and design, and coordinates timing of the work so that the new roof can be installed as soon as practicable after the new HVAC is done.

March 22, 2018

---

/s/ Justin C. Holland, Administrator  
City of Chattanooga  
Department of Public Works