

ADDENDUM NUMBER THREE
REPLACEMENT ROOFING SYSTEMS FOR
CARVER YFD CENTER
600 N. ORCHARD KNOB ROAD
FOR THE CITY OF CHATTANOOGA, TENNESSEE
Contract Number Y-17-007

The following questions have been received about the project:

Question 1: Some of the roofing projects recently advertised have had conflicting information for roofing associated sheet metal. Some specifications have called for 24 gauge Kynar steel, and conflicting specifications on the same project have called for 0.040 Kynar aluminum. Which is correct?

Answer 1: The City of Chattanooga, on all of the recently bid re-roofing projects, desire that the roofing associated sheet metal be 24 gauge Kynar coated steel.

April 2, 2018

/s/ Justin C. Holland, Administrator
City of Chattanooga
Department of Public Works