

## MEMORANDUM

TO: All Potential Proposers  
FROM: Jessica Carraher, Director of Business Services  
SUBJECT: Addendum #1, RFQ 2023-48, Parking Lot Resealing and Stripping  
DATE: May 1, 2023

---

1. See attached for revised Bid Form to be used for submitting Bid Response due on Wednesday, May 10, 2023, at 2:00 PM EST.
2. Approximately fill measurements by site are:
  - KFW – 1,000 LF
  - Courthouse – 5,000 LF
3. What type of Asphalt should be used?  
**Coal-tar concentrate**
4. What type of paint should be used?  
**DOT approved 1952-E type 1**

**REVISED**  
**BID FORM**

**RFQ 2023-48**  
**Parking Lot Resealing and Stripping**

Requirements listed in Section 1 of RFQ:

<b><u>Line</u></b>	<b><u>Description</u></b>	<b><u>Cost</u></b>
1	<u>5200 Jim Bilton Blvd., St. George, SC 29477 –</u> Courthouse Entrance Drive (5,000 LF)	\$
2	<u>201 Johnson St., St. George, SC 29477 –</u> KFW Parking Lot (1,000 LF)	\$
<b>Total (Line 1 + Line 2)</b>		\$
3	<u>Crack Fill (per linear ft.)</u>	\$

**Authorized Signature:** \_\_\_\_\_

**Company Name:** \_\_\_\_\_

**Address:** \_\_\_\_\_

**City, State, Zip:** \_\_\_\_\_

**Phone/Fax No.:** \_\_\_\_\_

**Comments:** \_\_\_\_\_  
\_\_\_\_\_