

ADDENDUM NO. 2

DATE: November 16, 2018

TO: All Bidders

FROM: Penny Owens, Assistant Purchasing Agent

SUBJECT: Addendum No. 2 – Chapman Highway/Henley Street & Blount Avenue Signal Upgrade Project

PROJECT NO.: 18EH-SG-0005

BIDS TO BE OPENED: November 21, 2018, at 11:00:00 a.m. Eastern Time

This addendum is being published to respond to questions asked by potential bidders regarding the above-referenced Invitation to Bid and to post the sign-in sheet from the pre-bid meeting. This addendum becomes a part of the Contract Document and modifies the original specifications as noted.

Questions Received

- 1. Q: Which sidewalks are being removed or installed? Is this to cover sidewalk work beyond just the sidewalks that are damaged as a result of the signal work?**

A: The remove and install sidewalk pay items are to cover sidewalk work being damaged during the project. Sidewalk has already been installed on the two corners on the north side of the intersection. Panels that are damaged during signal construction will need to be removed and replaced. Sidewalk for the south side of the intersection will likely be completed before the signal infrastructure will be installed.

- 2. Q: Are the pull boxes and conduit associated with the fiber optic cable (across Henley Street) part of the bidders' scope of work?**

A: No, sheets C3 (Fiber Optic Interconnect Plan), C4 (Fiber Optic Interconnect Plan) and C5 (Fiber Optic Interconnect Plan) are not included in this bid package. The pull boxes and conduit have been installed.

END OF ADDENDUM NO. 2