



THE CITY OF DAYTONA BEACH
OFFICE OF THE PURCHASING AGENT

Post Office Box 2451
Daytona Beach, Florida 32115-2451

Phone (386) 671-8080
Fax (386) 671-8085

ADDENDUM NO. 2

DATE: 11/14/2019
PROJECT: ITB 20103
HENRY LEE PARK IMPROVEMENTS

OPENING DATE: 11/20/2019

This addendum is hereby incorporated into the Bid Documents for the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to and shall take precedence over the original documents. Additions are indicated by underlining, deletions are indicated by ~~strikethrough~~.

1. Is all of the steel have to be hot dipped Galvanized?
on page S -101 what does the it says 24' 4" 7/256 section 5 on section 2 is says 24'4" ? which is right.

Answer: **The Structural Drawings are correct. See note on sheet S101 stating "All structural steel permanently exposed to the weather shall be hot dipped unless otherwise noted" The dimension difference you have commented on is because one is a plan view , the other a section that takes in account the true length of the beam, which is 24'-8" (Lets take off the 7 / 256)**

2. All other terms and conditions remain the same.

The Bidder shall acknowledge receipt of this addendum in Section 7 of the Bid Proposal Form.

The City of Daytona Beach

Kirk Zimmerman, CPPB
Buyer