
ADDENDUM

Posted Date: March 12, 2024

Solicitation No.: 24-51

Solicitation Name: Cable Infrastructure Installation for Tyner Middle High School

Subject: Addendum Number 3

The following represents clarification, additions, deletions, and/or modifications to the above referenced solicitation. This addendum shall hereafter be regarded as part of the solicitation. Items not referenced herein remain unchanged, including the response date. Words, phrases, or sentences with a strikethrough represent deletions to the original solicitation. Underlined words and bolded phrases or sentences represent additions to the original solicitation.

1. **ATTACHMENT: NONE**

2. **QUESTIONS/ANSWERS**

1.	On Page 11 letter F mentions providing surface mount raceway to all areas below the ceiling including surface mount boxes if an existing pathway is not usable. In a new build should there be a reason we can't use the provided stub out? If not, can you supply an expected number of outlets that we will need to provide the raceway?
Answer	Stub outs should be available everywhere, however, in certain instances, if it comes to this, HCS shall run the raceway.
2.	There are references to basket/cable tray throughout the drawings and specs, is it fair to assume the electrician will install all cable/basket tray?
Answer	Yes, exception may be a few small pieces in an IDF/MDF

BIDDER/PROPOSER IS ADVISED, YOU ARE REQUIRED TO ACKNOWLEDGE RECEIPT OF THIS ADDENDUM WHEN SUBMITTING A BID/PROPOSAL. FAILURE TO COMPLY WITH THIS REQUIREMENT MAY RESULT IN THE BIDDER/PROPOSER BEING CONSIDERED NON-RESPONSIVE.

ALL OTHER TERMS AND CONDITIONS OF THE SOLICITATION DOCUMENTS ARE AND SHALL REMAIN THE SAME.

Steven Hodgen

Steven Hodgen
Purchasing Supervisor