

ADDENDUM NO. 2

January 22, 2019

CITY OF HAVELOCK

HAVELOCK WATER TREATMENT PLANT STORM / DISCHARGE DRAINAGE IMPROVEMENTS

JOB NO. 2015020

DRAWING NO. W-3642

NCBELS LICENSE NO. F-0334

NCBOLA LICENSE NO. C312

A. SCOPE

This Addendum No. 2 consists of pages ADDENDUM 2-01 through ADDENDUM 2-01

BIDDERS are hereby notified of additions to the Contractor Proposal with Scope-of-Work as follow:

1. CONTRACTOR PROPOSAL

Page 3 of 03, DELETE last paragraph; ADD "Proposals for work of these three (3) Area(s) shall be submitted by the contractor and received by the City no later than **3:00 PM, January 29, 2019.**"

2. AREA 2 – DRAINAGE DITCH ADJACENT TO WTP AND PERPENDICULAR TO BROWN BOULEVARD

Page 2 of 03, ADD to the first paragraph, "See NOTE for Area 3".

Page 2 of 03, ADD paragraph, "In addition to existing rip-rap at WTP Effluent Discharge Outlet, install sixteen (16) cubic yards of Rip-Rap Class B about the Discharge Outlet in Area 3 and the elevated-storage-tank drain location in Area 2 as directed by the *engineer*."

3. AREA 3 – HEADWALLS, DRIVEWAY CULVERT AND DRAINAGE DITCH DOWNSTREAM FROM WTP AND PARALLEL TO BROWN BOULEVARD

Page 2 of 03, ADD paragraph, "NOTE: Typically, the water treatment plant discharges 50,000 to 100,000 gallons of water once a day with flow-rate between 500 GPM and 900 GPM. The *owner* cannot forego discharge for two or more consecutive days. However, with appropriate timely request from the *contractor*, the *owner* can schedule and forego discharge for any one-day."

B. GENERAL

This Addendum No. 2 is submitted this 22nd day of January, 2019. Each BIDDER is requested to acknowledge receipt of this Addendum by initialing and attaching same to the submitted Contractor Proposal with Scope-of-Work.

RIVERS & ASSOCIATES, INC.
107 East Second Street
Greenville, North Carolina 27858
(252) 752-4135

ADDENDUM 2-1 of 01

