



Invitation for Bid #16-057
STONE MEADOWS LIFT STATION DETENTION STORAGE ADDITION

ADDENDUM 1

Addendum issued August 16, 2016

A non-mandatory Pre-Bid Meeting will be held at City Hall, 310 W. Pearce Blvd, Wentzville, MO 63385 at 9:00am on August 19, 2016. A project site visit will immediately follow the pre-bid meeting; the job site is a restricted access area.

The following bidder question and City response is hereby incorporated into the Invitation for Bids:

Bidder Question: Can a bid be submitted based on a variant internal width / depth of structure that would make up the same required volume?

City Response: No. The box culvert dimensions were optimized based on the available permanent utility easement in addition to depth restrictions due to the pump operation levels in the wet well and rim elevations of adjacent sanitary manhole structures.

All other Terms and Conditions as applicable to this Invitation for Bid shall remain as stated.

This addendum forms a part of the contract documents and modifies the original bidding documents dated August 10, 2016. Contractor shall acknowledge receipt of this addendum in the space provided on the Bid Form (Exhibit A). Failure to do so may subject bidder to disqualification.

End of Addendum 1